Attachments can contain viruses that may harm your computer. Attachments may not display correctly.

Maria Dotson

From: ddecaron@pdapa.com [ddecaron@pdapa.com] **Sent:** Tue 5/24/2011 12:48 PM
To: Maria Dotson
Cc: 'Paul Penninger'; ron@stonebridgeluxuryhomes.com
Subject: Lot 1006 The Point Septic System
Attachments: Lot 1006 SS Rev 052411.pdf(460KB)

PIEDMONT DESIGN ASSOCIATES, P.A.

Suite 101 Westfield Center, 125 East Plaza Drive,

Engineering

Mooresville, North Carolina 28115
Surveying

Telephone (704) 664-7888 Fax (704) 664-1778
Planning

Email: ddecaron@pdapa.com

Maria,
Today I went to the residence because of some potential conflict with a wall that the builder is proposing. The wall would only impact the repair area and not the primary system. We are wanting to decrease the length of the longest pink line (Repair Line 5) and some of line 4 (Blue) if possible. The last revision that we did was to take two panels each off of lines 3, 4 and 5. We would like to take three additional lines off of lines 4 & 5 and push the laterals tight up against the 10 ft property setback. We can also add a panel to the top line in the front yard. (Repair lateral #1). Please look over and see if you have any questions. The contractor is proposing to install a wall to get down to the lower garages and wants to maintain 15 ft setback between the wall and lateral. Please confirm this email and let me know if you have any problems with what you are doing. Thanks for your help with this matter.

This electronic file provided by Piedmont Design Associates, P.A. to the client is for coordination purposes only.

The client agrees not to use this drawing and data, in whole or in part, for any purpose other than the referenced project. The client agrees to waive all rights to claim against Piedmont Design Associates, P.A. resulting in any way from any unauthorized changes or reuse of this drawing and data for any project by anyone other than Piedmont Design Associates, P.A.. The client shall not hold Piedmont Design Associates, P.A. liable for any damages resulting from errors, omissions or inaccuracies contained within the electronic file.

This media should not be considered a certified document. If a conflict between the hard copy and the transferred CADD information is discovered or if a variance is introduced in the CADD information from any source, the hard copy original signed and sealed documents shall prevail.

David M. DeCaron

Piedmont Design Associates, P.A.