IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 146752

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4624340904

APPLICANT: JOHN GIAMBRA APPLICANT ADDRESS: 918 C BRAWLEY SCHOOL RD. MOORESVILLE NC 28117

SITE ADDRESS: 108 WASHAM RD PHONE: ALT. PHONE:

SITE DIRECTIONS: BRAWLEY SCHOOL RD - TL WASHAM RD - ON RT CORNER

SUBDIVISION: WASHAM POINT SECTION: LOT # 1 LOT AREA: 1.451 AC DESIGN FLOW: 480 GPD L.T.A.R.: .3

Septic Tank 1000 (gal) STB 794 Date 4-15-11
Pump Tank (gal) PT Date
Pump Make Model Serial #
Nitrification Fields 1 # Lines 5 Linear Ft: ~~405~~ 410
Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A

☑ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI
System Description: GRAVITY 25% REDUCTION
Repair System Description: LP PPBPS
Maintenance Agreement Required: ☐ YES ☑ NO
☑ GRAVITY ☐ PRESSURE

☑ Residence No. Bedrooms 4
☐ Business No. Persons 8
☐ Other No. Employees
☐ Slab ☑ Crawl Space
☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☑ Private ☐ Public ☐ Community

Comments / Conditions: WATER TO BE DIVERTED AS SHOWN ON PLAN.
~~X~~ House is larger than submitted on original site plan, ~~X~~ new house plan will fit, pool must go where permitted, nothing else can shift towards septic ~~X~~

INITIAL SITE SKETCH

SEE S & ME's

PLAN.

AS BUILT SKETCH

410' INSTALLED QUIK 4

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☑ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☐ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: John M Giambra Date: 10-13-13 Installed by:

IMPROVEMENT PERMIT by: [signature] Date: 10/3/13 OPERATION PERMIT by: HOWARD Date: 11-6-14

AUTHORIZATION TO CONSTRUCT by: [signature] Date: 1-9-14 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK

Scale 1:60'

Plans

(House wide 88'6"
Depth - 65'6")

- Lot SKETCH BY JOHN GRAMBRA
  with SEPTIC INFO BY SITE
- SITE PROJECT # 1584-13-114

* SKETCH MUST ACCOMPANY 5-30-13 REPORT.