Date Issued 10-6-83

Serial No. 6678


ICAR (S) Permit No. 19895

T C. No. 001-361-62

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct, ___ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 19895, dated 9-30-83 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 11-6-83, after which date this permit shall be null and void. Lake Norman



PLOT OF SYSTEM

Permeability Rate P.S.

Liquid Capacity of Tank 1500 gal

Tank Construction p/c concrete

Absorption and or Nitrification Lines

Total Line Length 400'

Number of Lines 4

Distance from House 5'+

Distance from Property Line 10'+

Distance from Well 50'+

NAME OF OWNER David C. Beam

LOCATION OF PROPERTY 16505 Washam Rd.

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

4-100' x 3' x 12" stone trenches on 9' centers

Comments: _____

B Hamilton
Division or Section Head

Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-S-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY