IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 ☒ MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 174075 PIN # 4624 38 1858 DATE August 3, 2012

OWNER or APPLICANT Harris Construction Group PHONE: Business 704-295-0094 Home: 704-202-3797

OWNER or APPLICANT ADDRESS 9935-D Rea Rd Ste 210 Charlotte 28277

LOCATION / DIRECTIONS Brawley Sch Rd TR Mansfield TR Harwick on right

SUBDIVISION The Point BLOCK / SECTION 9 LOT # 955 LOT AREA 1.77Ac DESIGN FLOW 600gpd L.T.A.R. .25gpd/ft²

Septic Tank 1500 Gallons: STB 350 Date 4-19-12

Pump Tank ____ Gallons: PT ____ Date ____

Pump Make ____ Model ____ Serial # ____

Nitrification Field No Fields 1 No Lines 9 Linear Feet 630

Trench Width 36 Max. Trench Bottom Depth 36 Gravel Depth NA ☒ GRAVITY ☐ PRESSURE

☒ New System ☐ Repair ☐ Expansion System Type I II (III) IV V VI

System Description: 25 % Reduction Gravity

Repair System Description: LP High Capacity Infiltrator

Maintenance Agreement Required ☐ YES ☐ NO

☒ Residence No. Bedrooms 5 ☐ Business No. Persons ____ ☐ Other No. Employees ____

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☒ Community

Comments / Conditions

- Initial system with Flow divider splitting first 5 lines from last 4 lines. Place divider on packed level surface.
- Repair system 48" trench bottom no reduction in trench length.

Comments / Conditions

INITIAL SITE SKETCH

See Plan from SxME

Approved by ICHD

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☒ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☒ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: ____ Date ____

Improvement Permit by: Judy Melville Date 8-3-12

Authorization to Construct by: Judy Melville Date 8-9-12

SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: GUNTER GRADING

Operation Permit by: [signature] Date: 11-6-12

Existing System Inspected by: ____ Date: ____

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant