4624-46-2264


Date Issued 23 JUNE 78 Serial No. 1732 ICAR'S Permit No 13589

T C No 021-354-16

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct, ___ Alter or Repair the following individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied on application 13589 dated ✓ and this permit shall be void and of no effect if the information provided in the application is not true or correct. All work shall be completed on or before 23 JUNE 78 after which date this permit shall be null and void.



PLOT OF SYSTEM

Proposed Use: 6C

Tank Capacity: 1500 gal

Tank Construction: Precast Concrete

Approximate Ground Slope:

Trench Length: 495'

Number of Lines: 5

Distance from House: 10'

Distance from Property Line: 10'

Distance from Well: 50'+

NAME OF OWNER MARRIOTT

LOCATION OF PROPERTY 193 GARNSWOOD DR CHT S-6 Lot 505

This system shall meet all the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission and are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. **The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.**

Comments

Division or Section Head

Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-S-76

Environmental Health Department's Copy

The proposed / existing Kitchen & Bath renovation addition does not appear to impact the existing septic system.

**NOTE: No bedroom addition

Judy Melville REHS

Date: 4-29-11

ICHD-Environmental Health Division