IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 109595 PIN# ~~4624-27-5905~~ 4624-47-7598 DATE Jan 14, 03

OWNER OR CONTRACTOR Crescent Resources (Agent) The Point at Norman HHZ PHONE: Business _____ Home _____

ADDRESS 2214 Brawley Sch Rd. Mooresville, N.C. 28117

LOCATION Brawley Sch Rd. TL Torrence Chapel Rd. on Right

SUBDIVISION The Point BLOCK / SECTION 11 LOT 1108 LOT AREA 46,367 ft² SITE CLASS PS DESIGN FLOW 480 gpd L.T.A.R. .25

Septic Tank: 1000 Gallons; STB 338 Date 6-29-04

Pump Tank: 1000 Gallons; PT 283 Date 7-24-04

Pump Make: Gould S Model _____ Serial No. _____

Nitrification Field; No Fields 1 Square Feet 640/960 Linear Feet 320

No Lines 4 Trench Width 24" min 36" max Max Trench Bottom Depth 36"

☑ New System ☐ Repair System Type: I, II, III, ⓘ V, VI

System Description: LPP PBPS

Repair System Description: Same

Maintenance Agreement Required: ☑ Yes ☐ No

Gravel Depth NA

☑ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Bathrooms 4 No. Employees ____

☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☑ Public ☑ Community


Comments:/Conditions: OR 36" HALO'OC

REAR YARD NOT EVALUATED

Comments:/Conditions: Reviewed Building plans & Site plans 4/30/04, essentially in Compliance with IP. Checked lines 8/24/04 MT 3/16" hole drilled


1" = 50'

INITIAL SITE SKETCH



AS/BUILT SKETCH

Installed as Drawn



RW Torrence Chapel Rd

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 4/30/03 Installed by: Bobby Mayhew

Improvement Permit by: _____ date 1/14/03 Operation Permit by: _____ date 10/14/04

Authorization to Construct by: _____ RS date 4/30/04 Existing System Inspection by: _____ date

HEALTH DEPT. COPY: WHITE