ENT OF ENVIRONMENT AND NATURAL RESOURCES
N OF ENVIRONMENTAL HEALTH
TE WASTEWATER SECTION

PROPER

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: CRI
ADDRESS: _____ APPLICATION DATE _____
PROPOSED FACILITY: _____ DATE EVAL.
LOCATION OF SITE: lot 1159 PROPOSED DESIGN FLOW (.1949): 4 bdrm PROPERTY SIZE: _____
WATER SUPPLY: ☐ Private ☒ Public ☒ Well ☐ Spring ☐ Other _____ PROPERTY RECORDED.
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	2-4%	0-9	fsl	fri ss p					
		9-33	sbk/gr	fri ss p	Mottles common yellow			.25-.3	
		33-58	Mottled well	fri ss p	textural stop				
2		0-8	compacted	Hor layer					
		8-22	mottled pc	fri sb					
		22-57	Mottled Pc	fri ss p	textural stop			.3	
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)	Gr 25% Red	LPP 25%
Site LTAR	.25	.25

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: DHH
OTHER(S) PRESENT: Paul Pennington

COMMENTS: _____