4624563585


Date Issued 8-15-85 Serial No. 08400 ICAR(S) Permit No. 21086

T. C. No 90 001-353-39

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct ___ Alter or Repair the individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 21086 dated 8-8-85 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 9-15-85, after which date this permit shall be null and void.



Permeability Rate B5

Liquid Capacity of Tank 1500

Tank Construction PCC

Absorption and or Nitrification Line:

Total Line Length 270

Number of Line 3

Distance from House 5'+

Distance from Property Line 10'+

Distance from Well 50'

NAME OF OWNER COLLINS, EDWARD ARTHUR

LOCATION OF PROPERTY 16929 GREY FRIARS RD

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly

3 line x 90' long x 3' wide x 12" stone

Comments:

Division or Section Head

Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-S-76

The proposed / ~~existing~~ Picnic Shelter 24'x20' addition does not appear to impact the existing septic system.

**NOTE:

Judy Melville R.S.

Date: 12-20-12

ICHD-Environmental Health Division