DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

OWNER: CRC
ADDRESS: ___ APPLICATION DATE ___
PROPOSED FACILITY: ___ PROPOSED DESIGN FLOW (.1949): 1500 gpd DATE EVALUATED: 12-18-02
LOCATION OF SITE: Lot 113 Pond Trail PROPERTY SIZE: ___
WATER SUPPLY: ☐ Private ☒ Public ☒ Well ☐ Spring ☐ Other ___ PROPERTY RECORDED: ___
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-4	SL	fri ss sp	32" + low chroma matrix				.3
		4-18	mfsbk RC	fri ss sp					
2	21%	0-9	g-wksbk fri SL	fri ss sp	low-chroma matrix				.25-.3
		9-29	mfsbk RC	fri ss sp					
		29-53	wk sbk ppd CL	fri ss sp common gravel and rock					
3	New on Lot 114 Revised	0-7	gr fri SL	fri ss sp					.25-.3
		7-30	mfsbk RC	fri ss sp					
		30-48	mottled gr CL fri ss sp common rock						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)	LPP	LPP
Site LTAR	.25-.3	.25-.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS per 1956
EVALUATED BY: DRH
OTHER(S) PRESENT: Paul Hammond

COMMENTS: Lot Line Adjusted (area shown to 114) to facilitate easement for LPP