VISION OF ENVIRONMENTAL HEALTH:
N-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: CRT
ADDRESS: _____ APPLICANT: _____
PROPOSED FACILITY: _____ APPLICATION DATE: _____ DATE EVALUATED: 12-18-07
LOCATION OF SITE: Lot 111 Shell Point PROPOSED DESIGN FLOW (.1949): 480gpd PROPERTY SIZE: _____
WATER SUPPLY: ☐ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____ PROPERTY RECORDED: _____
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	0-7	gr wk sbk loam sl	fr sss sp					
	7-34	mk sbk RC	fr ss sp	Sandy loam matrix				
	34-50	wk sbk yel	fr sss sp	common yel/gry mottles				3
2	0-4	gr loam sl	fr sss sp					
	4-24	m sbk RC	fr ss sp					
	24-32	m sbk Rg cl	fr sss sp					3
	32-54	mass Rg LSC	fr sss sp					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
ilable Space (.1945)		
em Type(s)	LPP/RBS	LPP/RBS

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: DRH
OTHER(S) PRESENT: Paul Pennington