DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: CRL APPLICATION DATE _____
ADDRESS: _____ DATE EVALUATED: 12-12-02
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 460 gpd PROPERTY SIZE: _____
LOCATION OF SITE: Lot 11 Sec 7 Phase II Flint PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-7	SL transel	friasp					.25
		7-28	SL gr/sbl/RC	fr SP					
		28-38	(fragl) wtbk/gr/sl	fr sp co					
		38-5[illegible]	massive gl/sl/sp	fr sl/sp					
2	4-6%	0-26	SBK RC	fr sp					.3
		26-56	MFSBK RCL	fr sp/vfr sl/sp					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)	Gr 25% Red	Gr 25% Red
Site LTAR	~.25	~.25

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): RS
EVALUATED BY: DRH
OTHER(S) PRESENT: Paul Baumgarten

COMMENTS: _____