DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: CBC APPLICATION DATE ___
ADDRESS: ___ DATE EVALUATED: 12-12-02
PROPOSED FACILITY: ___ PROPOSED DESIGN FLOW (.1949): 460 gpd PROPERTY SIZE: ___
LOCATION OF SITE: Lot 1159 Phase II The Pt. PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☒ Public ☒ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-6	Wk Sbk vfr sl	fr ss sp					~.5
		6-20	wk sbk RC	wh ss sp					
		20-36	wk sbk rg scl	fr ss sp	common mn ss sp				
		36-75	mane rg scl ss sp	fr ss sp					
2		0-13	SBK RC	fr ss sp - sp					-.3
		13-43	wk sbk RCl	fr ss sp	common mn ss sp				
		43-62	wk sbk L scl sp	fr ss sp					
3		0-5	wk sbk vfr sl rbrk	fr ss sp					.35
		5-18	wk sbk RC	fr ss sp					
		18-56	wk sbk rg scl/l	fr ss sp	common mn ss sp				
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)	Gr 25% Red	Gr 25% Red
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: DWH
OTHER(S) PRESENT: Chad Freeman

COMMENTS: ___