ON-SITE WASTEWATER SECTION

Sheet ___ of ___

PROPERTY ID #: _____

COUNTY: _____

SOIL/SITE EVALUATION *for* ON-SITE WASTEWATER SYSTEM

OWNER: CRI

ADDRESS: _____ APPLICATION DATE _____

PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 4 bdroom DATE EVALUATED: Dec. 11, 02

LOCATION OF SITE: lot 1152 Shell Point PROPERTY SIZE: _____

WATER SUPPLY: ☐ Private ☒ Public ☒ Well ☐ Spring ☐ Other _____ PROPERTY RECORDED: _____

EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut

TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	~5%	0-9	fill sandy	loose					~3
		9-33	mottled SRC	firm					
		33-59	mottled yellow sand	loose	common organic lenses				
2		0-12	Compacted Sand						
		12-37	A/E sand weak	loose	low-common organic lenses				.25-.3
		37-55	mottled SL	loose					
3		0-8	fill						
		8-18	weak brown sand	loose					~.25
		18-41	mottled SC	firm	low-common organic lenses				
		41-55	mottled sandy	loose					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)	Gr 25% Ref pm/LP (deep) 25% Red.	
Site LTAR	.25-.3	.25-.3

COMMENTS: _____

OTHER FACTORS (.1946): _____

SITE CLASSIFICATION (.1948): PS

EVALUATED BY: DWS

OTHER(S) PRESENT: Paul Rimmington