DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Kenneth Banker Hunes — APPLICATION DATE _____
ADDRESS: _____ — DATE EVALUATED: _____
PROPOSED FACILITY: 5 BR SFD — PROPOSED DESIGN FLOW (.1949): 600 GPD — PROPERTY SIZE: _____
LOCATION OF SITE: Lot 1217, The Point S/D — PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut — TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1948 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFILE CLASS & LTAR
			.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	
1		0 - 5	Suspect fill						PS
		5 - 10	Wk, Gr, SCL	Fr, SS, SP	(Red)				
		10 - 40	Mo, Sbk, C	Fr, SS, SP	(Red)				0, 30
		40 - 48	Wk, Sbk, CL	Fr, SS, SP	(Red) w/	C-M Sap. Inclus.			
2		0 - 6	Suspect fill						
		6 - 12	Wk, Gr, SCL	Fr, SS, SP	(Red)				
		12 - 36	Mo, Sbk, C	Fr, SS, SP	(Red)				0, 30
		36 - 48	Wk, Sbk, CL	Fr, SS, SP	(Red) w/	F-C Sap Inclus.			
3		0 - 3	Suspect fill						
		3 - 20	Wk, Sbk, CL	Fr, SS, SP	(Red) w/	M Sap.	Inclus.		
		20 - 48	Mass., SL/L	Sap, Fr, SS, NP	w/ C - CL	Pockets			0, 30+
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

COMMENTS: _____