14917

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR Wm. Hladik DATE 7/17/92 AWS PERMIT NO. 2L-1-A-12

PHONE: Business _____ Home 366-5588

LOCATION YACHT HARBOR - BRAWLEY SCH - TL ON YACHT BEAR (E) TR into YACHT RD, TL ON KEEL TO LOT ON (L) JUST BEFORE CUL DE SAC S.R. No. _____

SUBDIVISION NAME YACHT HARBOR LOT NO. 12 SECTION OR BLOCK NO. _____

House ☑ Mobile Home ☐ Business ☐ Other _____

No. Bedrooms 3 No. Bathrooms 2-2.5

Garbage Disposal Unit Yes ☑ No ☐

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area .479 AC

Soil Characteristics P - C / SC


Application Rate P - .35 (F-SP-WK)

Topography P - 2-3%

Depth to Water Table S >48"

Rock or other impervious formations S - None observed

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓ Crawl Space



Plot of System (Not to Scale)

Size of Tank ST 1250 / PT 1089 + 1250 Gals.

Nitrification Field:

No. of Lines 3 @ 70' X 2' X 16" PPBPS DRAINLINES PRESSURE DOSED

Sq. Ft. _____ Linear Ft. 210

Depth of Stone in Lines 6" SAND & UNDER

Water Supply: Individual ☑ Public ☐

Installed by Nelson Hathcock Peninsula Grading

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY Wesley Sparks RS.

COMMENTS 120-125 GALS/DOSE - 29 GAL. PER MIN PUMP REQUIRED 1½ PVC RUN THROUGH PANELS CONTINUOUSLY WITH 3/16" HOLE DRILLED IN CENTER OF EACH PANEL - TURN HOLE UP INSIDE EACH PANEL - 2' PRESSURE HEAD AT END OF EACH DRAINLINE - GATE VALVE AT BEGINNING OF EACH DRAINLINE

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold