IREDELL COUNTY HEALTH DEPARTMENT 4624887436

11493

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR JRM Development DATE Sept. 7, '90 PERMIT NO 2C-1-A-11

PHONE: Business _____ Home _____

LOCATION 1100 TR 1101 TR into Yacht Harbour TR
atend of Cul-D-Sac

SUBDIVISION NAME Yacht Harbour LOT NO. 11 SECTION OR BLOCK NO. _____ S. R. No. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit	Yes (✓)	No ( )	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site ~~Suitable~~ RS	Yes (✓)	No ( )	

Lot Area 20000 ft²

Character & Porosity of Soil sl clay
Percolation Rate n.t.
Topography 2-4%
Depth to Water Table 4'+
Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 960 Linear Ft. 320
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Bobby Mayhew

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: Cul-D-Sac

CERTIFICATE OF COMPLETION BY _____ DATE Sept. 7, '90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold