11390

IREDELL COUNTY HEALTH DEPARTMENT

4624 888594

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR Thomas Delux DATE Jan 9, '92 PERMIT NO. 2C-1-B-10

PHONE: Business _____ Home _____

LOCATION 1100 TL Yacht Rd. on Right last lot on right past Yacht Harbour entrance

SUBDIVISION NAME Yacht Harbour S.R. No. _____

LOT NO. 10 SECTION OR BLOCK NO. _____

House ☑ Mobile Home ☐ Business ☐ Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area ~1/2 ac.

Soil Characteristics ls clay


Application Rate h.35

Topography 4-6%

Depth to Water Table 4'+

Rock or other impervious formations some scattered rock

Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓ Crawl Space _____



Plot of System (Not to Scale)

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 1020 Linear Ft. 340

Depth of Stone in Lines 12"

Water Supply: Individual ☑ Public ☐

Installed by Richard Abernathy

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY DR Hanson

COMMENTS Elevation of house appears to have been changed such that installation of original system had to be in what was originally designated as repair area. New repair area (to be pumped) is now above original installation and off the left rear of house. Saw grass over entire drainfield.

CERTIFICATE OF COMPLETION BY _____

EXISTING SYSTEM CHECKED BY DR Hanson, RS DATE 1-9-92

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS DATE _____

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold