4624 89 5332

12002

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Nelson McCrea DATE 6/28/91 PERMIT NO 2C-1-B-18

PHONE: Business _____ Home 663-5673

LOCATION 1100 TL Yacht Rd, TR into Yacht Harbour TR at Lake on (R)

S. R. No. _____

SUBDIVISION NAME Yacht Harbour LOT NO. 18 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2 1/2

Garbage Disposal Unit	Yes (✓)	No ( )	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil PS clay

Percolation Rate .3-1.35


Topography 2-4%

Depth to Water Table >48"

Rock or other impervious formations none observed

Lot Area 20,000 Ft²

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3 @ 70'

Sq. Ft. _____ Linear Ft. 210'

Depth of Stone in Lines _____

Water Supply: Individual (✓)

Public ( )

Installed by Richard Abernethy

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: Gravity panel with Dist. Box

CERTIFICATE OF COMPLETION BY Wesley Sparks RS. DATE 6/28/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold