7/15


Approval

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 6644A DATE: 7/15/94
001-341-10
TC: 041 141 93
SERIAL Nº 15788 R400

Permission is hereby given to ✓ Install or Construct, _____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 5/26/93. All work shall be completed on or before 8/15/94, after which date this permit shall be null and void. The system shall meet all of the construction requirements of ~~10 NCAC 10A .1900~~ 15A 18A which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Health Department before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Liquid Capacity of Septic Tank 1500 gallons
Liquid Capacity of Dosing Tank (2) 1000 gallons
Tank Construction PCC

Absorption and/or Nitrification Lines:
Trench Width 3 feet
Total Line Length 535 feet
Number of Lines 10 (53')
Depth of Stone 12 inches
Distance from House 5 feet
Distance from Property Line 10 feet
Distance from Well 750' feet

NAME OF OWNER Sara Seasholtz

LOCATION OF PROPERTY 16608 Wally Rd

Comments: 1500 ST, 1000 ST, 1000 holding tank, Flow divider, 2-D Boxes, 10 lines x 53' long x 3' wd x 12" stone | Keep septic system >50' from existing well. Pump to 1000 gal tank | Keep septic system 750' from high water mark. Protective sleeve to be installed under driveway.

Division or Section Head

Phillip S. Walker R.S.
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Mecklenburg County Health Department in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.