4624984140 25006 Sunfish Ct. 217

PROPOSED PLOT PLAN


HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON STREET
CHARLOTTE, NC 28202
PHONE (704) 336-5102

Lot owners TO be 6653A Vacant

FILE: ~~370283~~ New

TC: 001-342-15

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



Installation for 4 bedroom house, located at Lot 11, 25006 Sunfish Court.

Install:
- 1500 gal Septic Tank
- D-Box
- 4 nitrification lines
  - 3' x 133' x 12" stone/gravel
  - Trench Depth 24"-36"
- Divert gutter downspouts away from septic system
- Install surface water diversion ditches to near left and right property lines to divert water away from nitrification field, if necessary.

COMMENTS:
- Keep well 100' from septic system or maximum feasible distance, however, no well shall be within 50' of system.
- Any site changes or ~~site plan~~ changes intended use changes may void permit.
- DO NOT DISTURB or GRADE area for septic system + its designated repair area.

X ~~Diane B. Upham~~
OWNER/AGENT SIGNATURE

X DATE 10/17/95

APPROVAL DATE 10/19/95 Joan B. Malik, R

pg 2 of 2

White - Health Department's Copy Canary - E.H.S. Copy Pink - Owner's Copy