Pin 4624986084 Lake Norman Yacht Club Lot 3 Type 4 Inspection 1-30-02

07842

IREDELL COUNTY HEALTH DEPARTMENT 117 Melville Ct.

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Thomas Huggins DATE July 19 '88 PERMIT NO.

PHONE: Business Home

LOCATION 1100 TL Yacht Rd. (1182) Bear Ct. 1101 R at Meck Co. line Bear Ct. on left S. R. No.

SUBDIVISION NAME L. N. Yacht Club LOT NO. 3 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 3


Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site ~~Suitable~~ FS Yes (✓) No ( )

Lot Area .605 Ac.

Character & Porosity of Soil area of Chamfield clay
Percolation Rate ~35
Topography ~2%
Depth to Water Table 41+
Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

1000 gal pump tank



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. _____ Linear Ft. 180' 0/16"
Depth of Stone in Lines 24" proposed
Water Supply: Individual (✓) proposed-drilled
Public ( )

Installed by Wayne Robison

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DRH

COMMENTS:

CERTIFICATE OF COMPLETION BY D R Johnson, RS DATE July 19, 88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold