IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tom Guy DATE 11-9-87 PERMIT NO.

PHONE: Business Home

LOCATION 1100 TR 1182 (Yacht Rd.) TR 1101 TL just before Meck-Iredell Co. line Bear Rt. 1st lot on left S. R. No.

SUBDIVISION NAME Yacht Club LOT NO. 1 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2½


Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 20000 ft²+

Character & Porosity of Soil clay
Percolation Rate 1/35
Topography 2%
Depth to Water Table 3'+
Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

1000 gal pump tank



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 304 Linear Ft. 80'+ 6'
Depth of Stone in Lines 16" 12"
Water Supply: Individual (✓) panels
LAKE Public ( ) pressure dosed

Installed by Ray Beam

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY DKH

COMMENTS: Check alarm & well location DKH

Alarm OK, well location OK by K.S 3/17/88

CERTIFICATE OF COMPLETION BY [signature] DATE 3/17/88

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold