10-10-75

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tom Guy DATE 5-22-87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1109 TR 1182 (Yacht Rd) TR 1101 TR into Yacht Club (just before Meck Co. sign) on Rt. _____ S. R. No. _____

SUBDIVISION NAME Yacht Club LOT NO. 1 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 20000 sq ft

Character & Porosity of Soil clay

Percolation Rate 2.35


Topography 2%

Depth to Water Table 3'+

Rock or other impervious formations _____

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

1000 gal pump tank



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. _____ Linear Ft. 180'

Depth of Stone in Lines 16" ~~7~~ 8"

Water Supply: Individual (✓) panels

Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY D. R. Henson, RS

COMMENTS: Keep system shallow

CERTIFICATE OF COMPLETION BY [redacted] DATE [redacted]

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold