09168

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Claude Eugene Melton DATE Oct 31, '88 ~~PERMIT~~ NO. 20-D

PHONE: Business _____ Home _____

LOCATION 1100 TR 1236 (Stonemarker) ~3/4 - 1 mile on Rt 6

S. R. No. _____

SUBDIVISION NAME CL&T LAKE NORMAN LOT NO. 699 SECTION OR BLOCK NO. 6

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site ~~Suitable~~ PS Yes (✓) No ( )

Character & Porosity of Soil Class IV A clay
Percolation Rate 2, 4
Topography ~4%
Depth to Water Table 4'+
Rock or other impervious formations none obs.

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3 (Maybe 4)
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: [signature]

IMPROVEMENTS PERMIT BY DR Hinson, RS.

COMMENTS: Follow contour with drainfield. Install drainfield at a depth of 24" to trench bottom.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold