4625011561

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR W. O. Johnston DATE 11-29-79 PERMIT NO. 414

PHONE: Business _____ Home _____

LOCATION 1100 Ron 1236 ~1/4 mi on Rt. _____ S. R. No. _____


SUBDIVISION NAME Lake Norman LOT NO. 102 SECTION OR BLOCK NO. 6

House (✓) Mobile Home ( ) Business ( ) Other _____

w/addition

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clay loams
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	30 min.
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	25%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	sunk.
Lot Area ~3/4AC.			Rock or other impervious formations	none obs.



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 100 Linear Ft. 333
Depth of Stone in Lines 16"

Water Supply: Individual (✓)
Public ( )

Installed by F.J. Ervin

IMPROVEMENTS PERMIT BY DRH

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Henson DATE 11-29-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

2.00

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR W. O. Johnston DATE 8-3-79 PERMIT NO. 231

PHONE: Business _____ Home _____


LOCATION 1100 TR at Meck. Co. line onto 1236
2 1/4 mi on Rt S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 102 SECTION OR BLOCK NO. 6

House (✓) Mobile Home ( ) Business ( ) Other _____
w/ addition

No. Bedrooms 4	No. Bathrooms 3			Character & Porosity of Soil	clay loam
Garbage Disposal Unit	Yes ( )	No (✓)		Percolation Rate	50 mpi
Auto. Dishwasher	Yes (✓)	No ( )		Topography	25 - 35%
Auto. Wash. Machine	Yes (✓)	No ( )		Depth to Water Table	8'+
Site Suitable	Yes (✓)	No ( )		Rock or other impervious formations	some scattered rock

Lot Area ~3/4 AC



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 1000 Linear Ft. 333
Depth of Stone in Lines 16" +
Water Supply: Individual (✓)
Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY Harold R. Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold