WELL ABANDONMENT RECORD

North Carolina Department of Environment and Natural Resources- Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2123

1. WELL CONTRACTOR:

Marty Eklund
Well Contractor (Individual) Name

Eklund Pump & Well
Well Contractor Company Name

STREET ADDRESS 198 - Red Hawk

Olin NC 28660
City or Town State Zip Code

(704) - 876-8686
Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID # (if applicable)

STATE WELL PERMIT # (if applicable)

COUNTY WELL PERMIT # (if applicable)

DWQ or OTHER PERMIT # (if applicable)

WELL USE (Circle applicable use): Monitoring (Residential) Municipal/Public Industrial/Commercial Agricultural Recovery Injection Irrigation

Other (list use)

3. WELL LOCATION:

COUNTY Iredell QUADRANGLE NAME

NEAREST TOWN: Mooresville

(Street/Road Name, Number, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:
Slope Valley (Flat) Ridge Other
(Circle appropriate setting)

LATITUDE

LONGITUDE

May be in degrees, minutes, seconds, or in a decimal format

Latitude/longitude source: GPS Topographic map

(Location of well must be shown on a USGS topo map and attached to this form if not using GPS.)

4a. FACILITY- The name of the business where the well is located. Complete 4a and4b. (If a residential well, skip 4a; complete 4b. well owner information only.)

FACILITY ID #(if applicable)

NAME OF FACILITY

STREET ADDRESS 136 Rollingwood Lane

Mooresville NC 28117
City or Town State Zip Code

4b. CONTACT PERSON/WELL OWNER:

NAME Andrew Sifferly

STREET ADDRESS 209 Poplar Grove Rd

Mooresville NC 28117
City or Town State Zip Code

(704) - 634-5909
Area code – Phone number

5. WELL DETAILS:

a. Total Depth: ? ft. Diameter: 2 inch in. Well

b. Water Level (Below Measuring Point): 20 ft.

Measuring point is 1 ft. above land surface.

6. CASING:

	Length	Diameter
a. Casing Depth (if known):	2 ft.	4 in.
b. Casing Removed:	20 ft.	2 in.

7. DISINFECTION: Bleach

(Amount of 65%-75% calcium hypochlorite used)

8. SEALING MATERIAL:

Neat Cement — 5 Sacks

Cement ___ lb. Cement ___ lb.
Water 25 gal. Water ___ gal.

Sand Cement

Bentonite

Bentonite ___ lb.
Type: Slurry ___ Pellets ___
Water ___ gal.

Other

Type material Portland Cement

Amount

9. EXPLAIN METHOD OF EMPLACEMENT OF MATERIAL:

Mixed Straight Portland so it would flow in small hole to fill well

10. WELL DIAGRAM: Draw a detailed sketch of the well on the back of this form showing total depth, depth and diameter of screens (if any) remaining in the well, gravel interval, intervals of casing perforations, and depths and types of fill materials used.

11. DATE WELL ABANDONED 6-15-07

I DO HEREBY CERTIFY THAT THIS WELL WAS ABANDONED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Marty Eklund 6-21-07
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

6/21/07
SIGNATURE OF PRIVATE WELL OWNER ABANDONING THE WELL DATE
(The private well owner must be an individual who personally abandons his/her residential well in accordance with 15A NCAC 2C .0113.)

Marty Eklund
PRINTED NAME OF PERSON ABANDONING THE WELL

Submit a copy to the owner and the original to the Division of Water Quality within 30 days.

Form GW-30
Rev. 5/06

TY MAY BE SUBJECT TO RECORDED
ED RIGHTS OF WAYS OR EASEMENTS
.

ATION:
: 370313-0200 C
6-22-98

a Neighbor's Well

PORTION OF LOT #127
LINDA P. MARTIN
1179-573

ROLLINGWOOD LANE
60' R/W

50'

EX. #5 REBAR

R=113.56'
A=20.68'
CHORD: S 63° 56' 24" E 20.65'

UNMARKED POINT

A=55.71'
R=50.00'
CHORD: N 78° 41' 10" E 52.87'

EX. 1" ROD

S 29° 26' 53" E 34.07'

EX. #5 REBAR

N 38° 03' 52" E 240.06'

16.66'

EX. BENT #4 REBAR

WOOD BUILDING

PORTION OF LOT #127
0.813 ACRES +-

PROPOSED HOUSE

EXISTING WELL HOUSE

EXISTING 1-STORY FRAME HOUSE

50' LAKE SETBACK

N 66° 29' 57" W 89.00'

N 72° 53' 58" W 90.05'

25.96'

29.98'

S 08° 53' 02" W 219.35'

LOT #128
JAMES JULIAN
1316-1969
PB: 14-79

DEED BOOK: 1179-573 NORTH

DEDMON SURVEYS

A PORTION OF THIS PROPERTY DOES LIE WITHIN

LAKE NORMAN