DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Andy Sipperley
ADDRESS: _____ APPLICATION DATE _____
DATE EVALUATED: 4-17-07
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 600gpd PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____

WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____

EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	6-8%	0-4	sbk cl			48			.3
		4-30	sbk c	Gr ss sp					
		30-48	sbk cl	Gr ss sp					
2		0-4	gr l			48			.3
		4-25	sbk c	Gr ss sp					
		25-40	sbk cl						
		40-48	sbk scl						
3		0-3	sbk cl			48			.3
		3-28	sbk c	fr ss sp se					
		28-48	sbk cl						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	Yes	Yes
System Type(s)	LPP Panel	LPP Panel
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S Melville
OTHER(S) PRESENT: _____

COMMENTS: _____