IREDELL COUNTY HEALTH DEPARTMENT

ATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # _____ PIN # 4625 28 4180 DATE November 9, 2010

OWNER or APPLICANT Jonno Hanafin PHONE: Business 746-6497 Home: _____

OWNER or APPLICANT ADDRESS 296 Fairview Ave, Long valley, NJ 07853

LOCATION / DIRECTIONS Brawley Sch. Rd, TR Bay Harbour TR Hunters Point TL Pointe Harbour at end on right

SUBDIVISION Harbour BLOCK / SECTION 5 LOT # 39/39A LOT AREA .58 ac. DESIGN FLOW 720 gpd L.T.A.R. .3 gpd/ft²

Septic Tank 1500 Gallons: STB TW1500 Date PLASTIC

Pump Tank 1500 Gallons: PT TW1500 Date PLASTIC

Pump Make MYERS Model ME100 Serial # 1HP

Nitrification Field No Fields 1 No Lines 2 Linear Feet 200 ★

Trench Width 36" Max. Trench Bottom Depth 30" Gravel Depth NA ☐ GRAVITY ☒ PRESSURE

☐ New System ☐ Repair ☒ Expansion System Type I II III IV V VI

System Description: 2590 Reduction pm

Repair System Description: LP PPBPS

Maintenance Agreement Required ☐ YES ☒ NO

☒ Residence No. Bedrooms 6 ☐ Business No. Persons 12 ☐ Other No. Employees _____

☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☒ Community

Comments / Conditions ★ plus 400' existing

See specs for varying tap sizes

Comments / Conditions 11/18/2010 Checked 2 Drainlines

12-3-10 CHECKED TANKS - INFILTRATOR TANKS

INITIAL SITE SKETCH

Follow plan from Michael Athanas & Associates approved by ICHD

AS BUILT SKETCH

HAD TO INSTALL C3' BECAUSE OF PLUMBING/RISERS W/IN 6" OF GRADE

INSTALLED FILTER

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☒ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Dixie Dawn for Hanafin Date 11/10/10

Improvement Permit by: Sandy Melville Date 11-9-10

Authorization to Construct by: Sandy Melville Date 11-9-10

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: Richard Abernathy

Operation Permit by: [signature] REHS Date: 12-10-10

Existing System Inspected by: _____ Date: _____

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant

Approved
ICHD 11-5-10
gm