DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: CRI — APPLICANT: _____
ADDRESS: _____ — APPLICATION DATE: _____ — DATE EVALUATED: 7-25-96
PROPOSED FACILITY: _____ — PROPOSED DESIGN FLOW (.1949): _____ — PROPERTY SIZE: _____
LOCATION OF SITE: Septic Easements - near Windy Run — PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

X Change areas for Lot 8 & 54 & → SFEB, 54 → SFEA

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO GLASS	1944 RESTR. HORIZ.	PROFILE CLASS & LTAR
P1	D	0-4	gr brn sl	fr					PS .3+
1	L ~15%	4-16	SAB R	fr 1:1					
SFEA for Lot 8		16-30	ymsab RCL	fr 1:1					
		30-55+	SL SAP	fr					
P2	②	0-6	gr brn sl	fr					PS .3+
2	L ~15%	6-16	SAB RC	fi sp 1:1					
		16-32	wk SAB R light C/CL						
		32-48	wk SAB mas RCL/L sap	fr sp/mpr/wpr					
		48-58+	massive SL SAP	fr					
SFEB (54)		0-6	gr SL	fr					.02
3		6-23	wk SAB yR-rg SCL	fi fr ss sp					
		23-58	massive R-y, yb SL SAP some mottles RCL	fi fr ss sp					
P4		0-12	gr-SAB R brn SCL						.25
4		12-25	SAB RC	fi sp 1:1					
		25-38	wk SAB mas RCL	fi ss sp 1:1					
		38-52+	massive yR SAP	fi fr ss sp-mp					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____