HEALTH DEPARTMENT - ENVIRONMENTAL HEALTH ☐ STATESVILLE OFFICE 704-878-5305 ☒ MOORESVILLE OFFICE 704-664-5281

EMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

165225 PIN # 4625 38 4329 DATE November 16, 2011

OWNER Paul Foley APPLICANT: Michael Athanas PHONE: Home/Cell # Business #

SITE ADDRESS 413 Bay Harbour OWNER / APPLICANT ADDRESS 2051 Young Rd Pottstowne PA 19465

SITE DIRECTIONS Brawley School Rd TR Bay Harbour on left past Island Cove Ln

SUBDIVISION The Harbour BLOCK / SECTION 5 LOT # 13 LOT AREA 1.05 Ac. DESIGN FLOW 480gpd L.T.A.R. .33gpd/ft²

Septic Tank ~~1000~~ 1500 Gallons: STB 338 Date 4-30-11 ☒ New System ☐ Repair ☐ Expansion System Type I II III IV V VI

Pump Tank 1000 Gallons: PT 27 Date 11-29-11 System Description: 25% Reduction pm

Pump Make Model Serial # Repair System Description: LPPPBPS

No. Nitrification Fields: 1 No. Lines 3 Linear Feet 400 Maintenance Agreement Required ☐ YES ☒ NO

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth NA ☐ GRAVITY ☒ PRESSURE

☒ Residence No. Bedrooms 4 ☐ Business No. Persons 8 ☐ Other No. Employees ☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☒ Community

Comments / Conditions 11/17/2011 Reviewed Floor plans, in Compliance with original plan.

7/12/12 Checked ST & PT (installed as Drawn)
8/24/12 Drainlines Checked Quick 4

INITIAL SITE SKETCH

See Plan from Michanal Athanas & Assoc. Approved by TCHD

Flow Divider

PM

Supply Line

Some Repair

65'

65'

134'

134'

Some Repair

Bay Harbour Dr

AS BUILT SKETCH

Scale 1:50

PL 304.48'

ST

PT

Lake Norman

50' setback

House

Pool

Drive

revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

'T with plat valid without expiration. ☒ IMPROVEMENT PERMIT with plat valid without expiration. site plan valid 60/mo. ☐ AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT—not to exceed 60 mo.

Date 11/17/11 Installed by: Steve Jordan RS

REHS Date 11-16-11 OPERATION PERMIT by: REHS Date 9/17/12

REHS Date 11/17/11 Existing System Inspected by: REHS Date

LOCATOR SERVICE PRIOR TO ANY EXCAVATION

White Copy – Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant