IREDELL COUNTY HEALTH DEPARTMENT Const. Auth. STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / ~~CERTIFICATE OF COMPLETION~~ / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PROPERTY DESCRIPTION NO. 065697 DATE June 26 '97 TAX MAP NO. 4625941684 (pt.) 4625390064 Watershed: ☑ Yes ☐ No

OWNER OR CONTRACTOR Crescent Resources c/o ~~Jill Knudsen~~ Wayne Reit PHONE: Business _____ Home _____

ADDRESS PO Box 1003, Charlotte

LOCATION Brawley Sch Rd. TR Bay Harbour on Right ~500' past Shipyard Pt. Rd. 370 Bay Harbour Rd

SUBDIVISION The Harbour BLOCK / SECTION 6 LOT 53 LOT AREA 67129 SITE CLASS PS DESIGN FLOW 460 gpd L.T.A.R. .02-.025

Septic Tank: 1000 Gallons; STB 1012 Date 8-27-00

Pump Tank: 1000 Gallons; PT 1 Date 6-27-00

Pump Make: Hydromatic Model SHE50A1 Serial No. 127564

Nitrification Field: No Fields 1 Square Feet 1500 Linear Feet 500

No Lines 5 @ 100 Trench Width 36" Max Trench Bottom Depth 24" Gravel Depth NA

☑ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: pumped pgn chambered

Repair System Description: Chamber / LP Panel

Maintenance Agreement Required: ☐ Yes ☑ No

☑ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Bathrooms 4

☐ Business No. Employees ____

☐ Other ____

☐ Slab ☐ Crawl Space ☑ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☑ Community ☐ Public

Comments: RW Bay Harbour Rd.

Comments: 1"=50'

* ONE INSPECTION/OBSERVATION PORT per LATERAL

11-6-00 Press. Checked

11-1999 Reviewed house & site plan - apparently OK to move house to 65'

INITIAL SITE SKETCH

5 @ 100' Pump Chambered

Sch 80 pvc

10'

Repair AREA

60'x House

Old Rd Bed

Pt ST

Some Repair

Drainageway

220'

40'

AS BUILT SKETCH

DRIVEWAY

30'

WATER LINE

(Hardsurface) 220'

Off Left Side Of Upper 4 Lines Checked 11/2/2000 Poly Lock Filter Installed 11/3/00 Other Lines Checked

I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit is valid for 60 months from date of issuance.

Signed: _____

Improvement Permit by: _____ date 6-26-97

~~Existing System Inspection by:~~ _____ date 11-19-99

Installed by: Statesville Backhoe RS 4/23/2001

Certificate of Completion by: _____ date _____

Operation Permit by: _____ date 4/23/2001

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD