DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: CRT
ADDRESS: _____
APPLICANT: _____
APPLICATION DATE: _____
DATE EVALUATED: 5-10-96
PROPOSED FACILITY: SFR
PROPOSED DESIGN FLOW (.1949): 480 gpd
PROPERTY SIZE: _____
LOCATION OF SITE: Lot 57 Harbour
PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR. HORIZ	PROFILE CLASS & LTAR
1	V 4-6%	0-48	s-m f-m SAS leached	1:1	NA	>48"	N/A	N/A	.3
2	V 10-15%	0-10	gr. SAB R then sbk/SbL fr						.37
		10-34	SAB RC	f sp 1:1					
		34-48	SAB R then SbL fr few obs mottles						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____