3:00

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

DATE 1-10-07

PERMIT# 138689 PIN# 4625406615

OWNER OR APPLICANT ~~Chad Eaton~~ Robert Baykin PHONE: Business 704 987-5021 Home

ADDRESS PO Box 2393 Davidson NC 28036

LOCATION Crawley School Rd LB Lightship Dr. to end TR Thurston Ct

SUBDIVISION The Point BLOCK / SECTION 8 LOT 226 LOT AREA 87,363 ft² SITE CLASS PS DESIGN FLOW 480 L.T.A.R. .3

Septic Tank: 1000+ Gallons; STB 338 Date 8-29-08

Pump Tank: 1000 Gallons; PT 283 Date 6-23-08

Pump Make: Goulds Model WE-0312 Serial No.

Nitrification Field: No Fields 1 Square Feet 1200' Linear Feet 400'

No Lines 5@80' Trench Width 36" Max Trench Bottom Depth 36

Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type I II III IV V VI

System Description: Pump-fm-25% Reduction

Repair System Description: Same

Maintenance Agreement Required: ☐ Yes ☒ No

☐ Gravity ☒ Pressure ☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement wo/plumbing

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Persons

☐ Business No. Employees

☐ Other

Water Supply: ☐ Individual ☒ Public ☒ Community

Comments/Conditions: Lake Norman

Comments:/Conditions: Lake Norman 10/3/08 Check tanks

Scale 1:50

INITIAL SITE SKETCH

AS BUILT SKETCH

Note: Replaces prior permit issued 10-17-06; Tank location moved.

10/3/08 Checked lines Rick C.

Pool

Terrace

Proposed House

Drive

Thurston's Way

50

60

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed:

Improvement Permit by: RS date 6.28.07 Installed by: RS date 12/22/08

Authorization to Construct by: RS date 1/10/07 Operation Permit by: date

Existing System Inspection by: RS date 1/10/07

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK