DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: CRT
ADDRESS: ___
APPLICANT: ___
APPLICATION DATE: ___
DATE EVALUATED: 2-12-97
PROPOSED FACILITY: ___
PROPOSED DESIGN FLOW (.1949): 480 gpd
PROPERTY SIZE: ___
LOCATION OF SITE: Lot 16A Harbour Ln
PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 0 to 2%	0-3	gn brn sl/scl	fr					PS .3
		3-32	sbk r brn scl	fr ss sp sto					
		32-48	mott sbk gn, gry, brn scl	fr ss sp sto					
			common white flecks						
2	L 4-6%	0-2	sbk brn scl	fr ss sp sto					PS .3
		22-48	M-wk sbk gn, gry, brn cl	fr ss sp sto					
			common white flecks						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___