DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: CRI APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 5-10-96
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 480 gpd PROPERTY SIZE: ___
LOCATION OF SITE: Lot 50 Hebron phase III PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☑ Public ☑ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR-HORIZ	PROFILE CLASS & LTAR
1	L 2-4%	0-10	SAb R-brncL	fr					-3+
		10-38	SAb R-y CL heavy CLO	fr SS,sp li					
		38-48	SAb R-y CL	fr SS,sp li					
			few y-brn mtlx	mottles					
2	L 2-4%	0-10	SAb R-brncL	fr SS,sp li					-3+
		10-23	SAb RCL	fr SS,sp li					
		23-48	SAb R-y CL	fr SS,sp li					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___