DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Toney C. Jacobs, CPSS OWNER: ____ AGENT: ✓ PHONE: 663-6905
ADDRESS: Crescent Resources Inc. APPLICATION DATE: ____ DATE EVALUATED: ____
PO Box 1004 PROPOSED FACILITY: SFR 360 gpd
Charlotte NC PROPERTY SIZE: ____
LOCATION OF SITE: the Harbour phase I map C lot 72
WATER SUPPLY: On-Site Well ____ Comm. Well ✓ Public ____ Other ____ EVAL. METHOD: Auger Boring ____ Pit ____ Cut ____

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS	HORIZON LTAR
1	LSS	0-8	~~SAB~~/SCL						.3
		8-30	SAB/C						
		30-43	wk SAB/CL						
2		0-8	SAB/CL						.3
		8-13	SAB/CL						
		13-34	SAB/C						
		34-43+	wk SAB/CL						
3									
4									
5									

AVAILABLE SPACE (.1945): U SITE CLASSIFICATION (.1948): U SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: [signature] OTHER(S) PRESENT: K Sheeks, T Jacobs
COMMENTS: Site can be reclassified PS per rule .1956 Modified September PP'B'PS