DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Tony C Jacobs CPSS OWNER: AGENT: ✓ PHONE: ____
ADDRESS: Crescent Resources APPLICATION DATE: DATE EVALUATED: 7-22-94
PO Box 1003 PROPOSED FACILITY: SFR 480 gpd
Charlotte PROPERTY SIZE: ____
LOCATION OF SITE: The Harbour Lot 43 Phase I Map D
WATER SUPPLY: On-Site Well ____ Comm. Well ____ Public ✓ Other ____ EVAL. METHOD: Auger Boring ____ Pit ✓ Cut ____

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS	HORIZON LTAR
1		0-3	sl	-	-	-	P	-	-
		3-10	cl wk sbk	mod fri	-	-	P	-	0.4
		10-25	c wk sbk	mod fri	-	-	P	-	.3-.25
		25-47	sic wk sbk	mod fri	>47	>47	P	-	.3
2		0-3	→ same as	(1) ←					
		3-10							
		10-25							
		25-47							
3									
4									
5									

AVAILABLE SPACE (.1945) ____ SITE CLASSIFICATION (.1948): ____ SITE LONG-TERM ACCEPTANCE RATE: 0.3
EVALUATED BY: AL OTHER(S) PRESENT: NONE
COMMENTS: ____