VISION OF ENVIRONMENTAL HEALTH
-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM


OWNER: _____
ADDRESS: _____ APPLICANT: _____
PROPOSED FACILITY: _____ APPLICATION DATE: _____ DATE EVALUATED: 8-2-01
LOCATION OF SITE: Lot 858 plus 8 ToP. PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____ PROPERTY RECORDED: _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
(1)	0-8	g-wksbk brn sdl						
	8-16	wksbk brn R cl	fr sst					
	16-32	sbk brn RC	fi-fr sp-sst	common manganese coatings				.25
	32-48	wksbk yrcl	fi-fr sst	few brn mottles @ horizon change				
(2)	0-5	gr brn sdl	fr sst					
	5-24	mksbk yr c	fr-sp-sst					
	24-50	wksbk yr-ryc	fr-sp	few common mn stn				.3
N/3	0-36	sbk RC	fi-fr sp	very few brn mottles				
	36-50	sbk rcl	fr sst					.3

Available Space (.1945)
System Type(s)

SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

856
42,901 sq. ft.
858
42,327 sq. ft.
THURSTONS PLACE
50' PUBLIC R/W
25' SIDE YARD SETBACK
35' FRONT SETBACK
SETBACK
849 sq. ft.
39,204 sq. ft.
794 sq. ft.
188'
167'
117'
118'
235'
108'
198'
34'
58'
142'
104'
92'
91'
54'
53'
785
786
795


855
39,204 sq.ft.
856
42,904 sq.ft.
858
42,327 sq.ft.
38,294 sq.ft.
THURSTONS PLACE
50' PUBLIC R/W
25' SIDE YARD SETBACK
35' FRONT SETBACK
146'
49'
198'
144'
237'
118'
235'
117'
188'
167'
198'
142'
104'
92'
53'
34'
99'
91'
54'
38'
108'
795