IREDELL COUNTY HEALTH DEPARTMENT - *ENVIRONMENTAL HEALTH* ☐ STATESVILLE OFFICE 704-878-5305 ☒ MOORESVILLE OFFICE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

$350.00 02-16-C MS

PERMIT # 170481 PIN # 4625 52 8755 DATE February 14, 2012

OWNER Rov Investments LLC APPLICANT: Georgia Campbell PHONE: Home/Cell # 704-662-3292 Business # 791-1312 Jamie

SITE ADDRESS 187 Attleboro Pl Mooresville OWNER / APPLICANT ADDRESS 191 Shelbourne Pl. Mooresville

SITE DIRECTIONS Brawley School Rd TR Attleboro at end on left

SUBDIVISION The Point 390 BLOCK / SECTION 7 LOT # 717/717A LOT AREA 1.063 Ac. DESIGN FLOW 480 gpd L.T.A.R. .25 gpd/ft²

Septic Tank 1500★ Gallons: STB 352 Date 12-15

Pump Tank 1000 Gallons: PT 363 Date 11-13-12

Pump Make Orenco Model Serial #

No. Nitrification Fields: 1 No. Lines 4 Linear Feet 480

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type I II (III b) IV V VI

System Description: 25% Reduction Pump PM

Repair System Description: LP PPBPS

Maintenance Agreement Required ☐ YES ☒ NO

☐ GRAVITY ☒ PRESSURE

☒ Residence No. Bedrooms 4

☐ Business No. Persons

☐ Other No. Employees

☐ Slab ☒ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☒ Community

Comments / Conditions ★ Per The Point Subdivision Septic Specs. S.T = 390

Renewed Floor plans 2/18/13 in Compliance With Original plan. Note: Future Expansion Area Can not be a bedroom Unless Septic is upgraded.

INITIAL SITE SKETCH

See Plan from Adrian L. Pruitt, LSS

Approved by ICHD

Plat submitted is prepared by a registered land surveyor

AS BUILT SKETCH

2/21/13 Installed Quick 4 Infiltrator As Drawn

3/20/13 Checked ST & PT

7/12/13 Set 3Ft pressure, Checked float & alarm

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☒ ***IMPROVEMENT PERMIT*** *with plat valid without expiration.* ☐ ***IMPROVEMENT PERMIT*** *with plat valid without expiration. site plan valid 60 mo.* ☐ ***AUTHORIZATION TO CONSTRUCT*** valid for period equal to IMPROVEMENT PERMIT–not to exceed 60 mo.

Owner / Applicant Signature: Marie Lilley for Georgia Campbell Date

IMPROVEMENT PERMIT by: Judy Melville REHS Date 02-14-12

AUTHORIZATION TO CONSTRUCT by: Marie L. Pruitt REHS Date 2/18/13

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION

Installed by: Specialty Septic

OPERATION PERMIT by: Marie L. Pruitt REHS Date 7/12/13

Existing System Inspected by: REHS Date

White Copy – Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant