IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 ☒ MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 173471 PIN # 4625 53 5080 DATE July 2, 2012

OWNER or APPLICANT Michael & Joanne Dobbins PHONE: Business 704-528-9219 Home:

OWNER or APPLICANT ADDRESS 403 Barber Ln Mooresville 28117

LOCATION / DIRECTIONS Brawley School Rd TR Attleboro at end 193 Attleboro Pl.

SUBDIVISION The Point BLOCK / SECTION 7 LOT # 715/715A LOT AREA .964Ac DESIGN FLOW 600gpd L.T.A.R. .3gpd/ft²

Septic Tank 1500 Gallons: STB 390 Date 12-23-11

Pump Tank 1500 Gallons: PT 353 Date 1-28-12

Pump Make Ironco Model ____ Serial # ____

Nitrification Field No Fields 1 No Lines 5 Linear Feet 540

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth NA ☐ GRAVITY ☒ PRESSURE

☒ New System ☐ Repair ☐ Expansion System Type I II IIIb IV V VI

System Description: 25% Reduction pm

Repair System Description: 25% Reduction pump

Maintenance Agreement Required ☐ YES ☒ NO

☒ Residence No. Bedrooms 5 ☐ Business No. Persons ____ ☐ Other No. Employees ____

☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☒ Community

Comments / Conditions

Septic field located on offsite easement

Comments / Conditions Tanks 5ft from House MD

12/18/12 Checked tanks

1/10/13 Checked 3 upper lines

1/11/13 Checked other 2 lines

INITIAL SITE SKETCH

See Plan from Jacobs On-Site Development, Inc.

Approved by IEHD

AS BUILT SKETCH

Installed Quick 4

5/10/13 Set pressurehead @ 3ft

Checked elect & alarm

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ IMPROVEMENT PERMIT w/ plat valid without expiration. ☒ IMPROVEMENT PERMIT w / site plan valid for 60 mos. ☐ AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.

Applicant Signature: [signature] Date 7/3/12

[signature] Date 7-3-12

Date 8-1-12

ANY EXCAVATION.

Installed by: Specialty Septic Date: 5/10/13

Operation Permit by: [signature] RS

Existing System Inspected by: ____ Date: ____

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant