DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: MI Homes OWNER: AGENT: PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: ____
PROPOSED FACILITY: ____
PROPERTY SIZE: ____
LOCATION OF SITE: Lot 46 Harbour
WATER SUPPLY: On-Site Well ____ Comm. Well ____ Public ____ Other ____ EVAL. METHOD: ____

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	LSS 4-6	0-12	RC SBK	FI SS SP					KS .3
		12-38	CC MSBK	FRI SS SP					
		38-46	CCL WSBK	FRI SS SP					
2	↓	0-6	SCL GR	FRI SS SP					KS .3
		6-24	CL SBK	FR S P					
		24-46	CL WSBK	FRI SS SP					
3									
4									
5									

USABLE SPACE (.1945) ____ SITE CLASSIFICATION (.1948): ____ SITE LONG-TERM ACCEPTANCE RATE: ____

EVALUATED BY: ____ OTHER(S) PRESENT: ____

COMMENTS: ____

DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Toney Jacobs CPSS
ADDRESS: Crescent Resources Inc. / PO BOX 1003 / Charlotte NC 28201
OWNER: ↘ AGENT: ___ PHONE: ___
APPLICATION DATE: ___ DATE EVALUATED: 7-18-94
PROPOSED FACILITY: SFR 360 gpd
PROPERTY SIZE: ___
LOCATION OF SITE: The Harbour Lot 46 phase I map D
WATER SUPPLY: On-Site Well ___ Comm. Well ↘ Public ___ Other ___ EVAL. METHOD: Auger Boring ↘ Pit ↘ Cut ___

PROFILE	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1B		0-8	cl wk sbk		–	–	–	–	–
		8-14	c wk sbk		–	–	P	–	0.3
		14-42	sic wk sbk	dh/ws wp	–	–	P	–	0.25
		42-45	sic f Saprolite	mfr	–	–	P	–	0.3
		45-48	Saprolite		>48	48	–	U	–
1P		0-6	fsl		–	–	P	–	–
		6-12	fscl		–	–	P	–	–
		12-20	c vwk mod cess sbk	mafi-mafi	–	–	P	–	–
		20-??	Saprolite f clay	mafi massive	~30	~36	U	U	–
2P		this pit similar to 1B but with only about 40" of usable profile.							
4									
5									

AVAILABLE SPACE (.1945): P SITE CLASSIFICATION (.1948): P SITE LONG-TERM ACCEPTANCE RATE: 0.25
EVALUATED BY: AL. OTHER(S) PRESENT: NONE
COMMENTS: ONSITE CONV. INITIAL & REPAIR