DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: CRI OWNER: ____ AGENT: ____ PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: 8/29/95
PROPOSED FACILITY: ____
PROPERTY SIZE: ____
LOCATION OF SITE: Harbour Pt Septic Easement Areas Lot 51 (for 47, 48, 49)
WATER SUPPLY: On-Site Well ____ Comm. Well ____ Public ____ Other ____ EVAL. METHOD: Auger Boring ____ Pit ____ Cut ____

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	49A	0-7	SAB CL	fr					.3+
		7-27	MSSAB fsl/c-lsc/c	fi, ss, sp					
		27-48	m-wSAB CL	fr					
2	13A	0-7	gr- sl	fr					.3+
		7-	fr lsc/c	fi, sp					
		24-	lsc	lo					
3	49A	0-8	gr - SL	1:1 fr					.3+
		8-14	mSAB CL	1:1 fr					
		14-29	MS-SAB C	1:1 fi, sp					
		29-48+	m-wSAB CL	1:1 fr					
4									
5									

AVAILABLE SPACE (.1945): ____ SITE CLASSIFICATION (.1948): ____ SITE LONG-TERM ACCEPTANCE RATE: ____

EVALUATED BY: ____ OTHER(S) PRESENT: ____

COMMENTS: ____