IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# REPAIR PIN# REPAIR 4025585835 DATE 4/3/98

OWNER OR CONTRACTOR MI HOMES PHONE: Business 376-9800 Home

ADDRESS 1043 E. MOREHEAD ST, CHARLOTTE NC

LOCATION (LOT 30) - BAY HARBOUR - TL LAKE MIST - TL SUNRISE ON (L) - (LOT 54) BAY HARBOUR - TL LAKE MIST ON RT.

SUBDIVISION HARBOUR BLOCK / SECTION I, II LOT 30, 54 LOT AREA ~36,000 ft² SITE CLASS. PS DESIGN FLOW 767 GPD L.T.A.R. .3 gal/ft²

Septic Tank: EXISTING Gallons; STB Date

Pump Tank: 1000 Gallons; PT 27 Date 6/23/98

Pump Make: HYDROMATIC Model SMEF100A Serial No. 6/98

Nitrification Field: No Fields 1 Square Feet 1920 Linear Feet 640

No Lines 8@80 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A

☑ New System ☑ Repair System Type: I, II, (III), IV, V, VI

System Description:

Repair System Description: PUMP CHAMBERED OR HDS

Maintenance Agreement Required: ☐ Yes ☑ No

☑ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Bathrooms 4

☐ Business No. Employees

☑ Other BASED ON WATER USE.

☐ Slab ☐ Crawl Space ☑ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☐ Public ☑ Community

Comments:/Conditions:

Comments:/Conditions:

INITIAL SITE SKETCH

SEE ATTACHED SITE PLAN

AS BUILT SKETCH

I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Tony Clark, CRS (Agent) date 4/7/98

Improvement Permit by: C. Ray Thomas RS date 4/3/98

Authorization to Construct by: C. Ray Thomas RS date 4/3/98

Installed by: Macleod Const

Operation Permit by: Wesley Sparks RS date 8/12/98

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD