DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: CRF OWNER: AGENT: PHONE: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 8-2-95 pm
PROPOSED FACILITY: ___
PROPERTY SIZE: ___
LOCATION OF SITE: Lot 11 Harbour II
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ✓ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1		0-12	gr-wksbk/blocky	fr/ss sp					.3
		12-40	wksbk/blocky	fr/ss sp					
2		0-12	wksbk cl	fr					
		12-36	mksbk cl	fi/ss sp					
		36-45+	mksbk cl	fi ss sp					
3		0-5	gr-lm sil	fr					.3
		5-43	blocky cl	fr					
4									
5									

AVAILABLE SPACE (.1945) ___ SITE CLASSIFICATION (.1948): ___ SITE LONG-TERM ACCEPTANCE RATE: ___
EVALUATED BY: ___ OTHER(S) PRESENT: ___
COMMENTS: Vans completed type w/ gas in system. Locating lot, Marks
Some Hydric Properties - 50' setback from ... Lot 12 ... 8/21/95