DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET____OF____
PROPERTY I.D.#:_____
PROPERTY RECORDED:_____
COUNTY:_____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Sawsey Barbour OWNER:__AGENT:__ PHONE:_____
ADDRESS:_____ APPLICATION DATE:_____ DATE EVALUATED: 10/10/94
PROPOSED FACILITY:_____
PROPERTY SIZE:_____
LOCATION OF SITE: lot 56 The Harbor
WATER SUPPLY: On-Site Well____Comm. Well___Public___Other_____EVAL. METHOD: Auger Boring___Pit___Cut___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1		0-41	SAB / C	1:1 / fi-vfi			PS		.3
		41+	wk SAB / SAP-SIC trans	1:1 / fi-vfi					
2		0-30	SAB / C	1:1 / fi-vfi					.3
		30-43	wk SAB / SIC	1:1 / fi					
		43+	SIC - SAP trans						
3									
4									
5									

AVAILABLE SPACE (.1945): 4 SITE CLASSIFICATION (.1948): 4 SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: [illegible] OTHER(S) PRESENT: Jeff Commander/SB
COMMENTS: Keep trenches shallow - 24" ft depth, Site can be reclassified PS per rule .1956, mod/fed systems, PBBS