DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Toney Jacobs CPSS OWNER / AGENT: ____ PHONE: ____
ADDRESS: Crescent Resources Inc / APPLICATION DATE: ____ DATE EVALUATED: 7-18-94
Po Box 1003 PROPOSED FACILITY: SFR 360 gpd
Charlotte NC 28201 PROPERTY SIZE: ____
LOCATION OF SITE: The Harbour Lot 51 phase I map D
WATER SUPPLY: On-Site Well ____ Comm. Well / Public ____ Other ____ EVAL. METHOD: Auger Boring / Pit ____ Cut ____

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1		0-9	el wk sbk	dh	-	-	-	-	
		9-33	c wk sbk	dh	-	-	P	-	0.3
		33-48	sic wk sbk	dsh	>48	>48	P	-	0.3-.25
2		0-9	el wk sbk				P		
		9-30	c wk sbk				P		0.3
		30-43	sic wk sbk		>43	>43	P	-	0.3-.25
			Saprolite						
3									
4									
5									

AVAILABLE SPACE (.1945) P SITE CLASSIFICATION (.1948): P SITE LONG-TERM ACCEPTANCE RATE: 0.25
EVALUATED BY: AL OTHER(S) PRESENT: NONE
COMMENTS: PPBPS repair possible if space is limited