VISION OF ENVIRONMENTAL HEALTH
N-SITE WASTEWATER SECTION

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

APPLICANT: Same
OWNER: C L & T
ADDRESS: PO Box 1003 CHARLOTTE
APPLICATION DATE:
DATE EVALUATED:
PROPOSED FACILITY: Res
PROPOSED DESIGN FLOW (.1949): 480
PROPERTY SIZE: 64000 ft²
LOCATION OF SITE: Lot 617 Point
PROPERTY RECORDED: N/A
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	LSS 4%	0-7	SiL GR	FRI SSSP					PS .4
		7-29	RC MFSBK	FRI SP					
		29-52	YR L MFSBK	FRI SS SP					
2		0-4	SiL GR	FRI SSSP					PS .3
		4-24	RC MFSBK	FRI SP					
		24-50	YR L WSBK	FRI SSSP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
vailable Space (.1945)	1200	1200
ystem Type(s)	1/1	1/1
te LTAR	.3	.3

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):
EVALUATED BY: Freeman
OTHER(S) PRESENT: Paul Pennington

760
154'
220'
145'
90'
765
770
775
465'
DRIVE
DRIVE
DRIVE
DRIVE
617
64,281 Sq. Ft.
618
58,211 Sq. Ft.
616
37,540 Sq. Ft.
261'
262'
18+00
19+00
16+00