VISION OF ENVIRONMENTAL HEALTH:
-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Owner APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 8-25-01
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: lot 710 sec 7 The Rt PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
(1) Sum	0-4	wk sbk brn scl	fr					PS .3
	4-37	Sbk rd c	fr sp ss ep					
	37-54	wk sbk red	few-com mod sap	fr ss ss				
10M TC	0-7	sg brn scl	fr ss sp					PS .3
	7-33	Sbk Red	fi-fr ss sp					
	33-55	wk sbk red	few mod sap	fr ss sp				
11M TC	0-6	sg brn scl	fr ss sp					PS .3
	6-25	wk sbk r brn scl	fr ss sp					
	25-50	sbk red	fr ss sp					

	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

ATTLEBORO PLACE
DRIVE
253'
235'
246'
236'
710
43,066 sq. ft.
709
32,930 sq. ft.
708
33,434 sq. ft.
60 x 90 Basement
Carport
R=200.00'
L=59.37'
Tan=29.97'
Delta=17°00'30"
R=254'
L=96.79'
50'
90'
140'
15' SIDE YARD SETBACK
189°52'02"
30.58'
279°52'02"
572.99'
10'x70'
SIGHT TRI.
Approved with Conditions