DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Torey Jacobs, CPSS OWNER: ↘ AGENT: ↙ PHONE: ____
ADDRESS: Crescent Resources APPLICATION DATE: ____ DATE EVALUATED: 6-20-94
PROPOSED FACILITY: SFR 360 gpd
PROPERTY SIZE: ____
LOCATION OF SITE: Harbour lot 16
WATER SUPPLY: On-Site Well ____ Comm. Well ↘ Public ____ Other ____ EVAL. METHOD: Auger Boring ↘ Pit ↘ Cut ____

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS	HORIZON LTAR
1		0-4	fsl		-	-	P	-	
		4-17	sic wk med sbk	mfi-vfi	-	-	P	-	0.25
		17-42	sic wk med sbk	mfi	>42	>42	P	-	0.3-.25
2		Pit 1 confirms profile of auger boring - pit 2 due to landscape position is standing water unable to evaluate							
3									
4									
5									

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): P SITE LONG-TERM ACCEPTANCE RATE: 0.25
EVALUATED BY: AL. OTHER(S) PRESENT: D.H.
COMMENTS: surface water diversion upslope of system avoid drainage way - see diagram.