21628

PROPERTY DESCRIPTION

Call Sanitarian Between 8 a.m. and 9 a.m. 664-5281 / 878-5305

APPLICATION FOR- (Not a Permit) (✓) Improvements Permit (✓) Zoning Permit ( ) Special Use ( ) Subdivision Approval ( ) Other

Proposed Use: S. F. House

Location: Rt. into The Harbour - left onto Lakeside Dr. - left onto Bay Point Lane

TAX MAP NO. _____

Tax Map No.	Township	Jurisdiction	Zoning
2E-12-A-13	Davidson	Iredell	R-20 (CUD)

Subdivision/Mobile Home Park	Lot No.	Lot Size	Flood Plain
The Harbour	13		Panel 200 ( ) yes (✓) no

Approx. Area to be disturbed	Street Address	Phone	Watershed
	125 Bay Point Lane		WS 4-CA


REQUIRED INFORMATION FOR IMPROVEMENTS PERMIT - IREDELL COUNTY HEALTH DEPARTMENT

SKETCH MAP

On the lot to be built on or to be used, show the property lines and the actual dimensions of the lot, the size and shape of any and all buildings located or to be located on the lot showing the distances from lot lines. Show setback of main building on adjacent lot and their use.

$15 Fee
$25 Late Fee
$40

92158



OWNER	ADDRESS	PHONE NO.
John William Homes	8305-D Arrowside Blvd. Ch. N.C.	522-9200

I certify that all of the statements made in this application and any attached documents are true, complete and correct to the best of my knowledge and belief and are made in good faith. I understand that false information may be grounds for rejection of this application. Authorized Health Department and Inspection Department Representatives are granted right of entry to make evaluations or inspections and to release information upon public request.

[signature] 7-6-95

Signature of Owner or Authorized Agent — Application Date

If permitted, the following minimum zoning requirements must be met, unless the Health Department requires more land area or other qualifications are indicated in the remarks.

Lot area 21,780 sq. ft. Front yard depth 35 ft. Corner yard depth 25 ft.
Lot width 130 ft. Side yard depth 15 ft. Rear yard depth 35 ft.

LAND USE INDICATED (is) (is not) PERMITTED IN THE ZONING DISTRICT.

REMARKS: Front bldg line to be at least 100' wide

ZONING ADMINISTRATION DIVISION

PC Carroll — 7-6-95

Approved by — Date

WHITE: Original CANARY: Inspection Copy PINK: Health Dept. GOLD: Owner